AIR EMISSIONS FROM A TAYMAC BOILER TRIALING WOODCHIP AT SOUTHERN INSTITUTE OF TECHNOLOGY



INTRODUCTION



SPEAKERS

Lloyd McGinty, Wood Energy Technical Advisor Support

- About SIT
- What are the drivers for trailing woodchip
- Methodology
- Results
- Lessons learnt
- Emissions from other boilers

ABOUT....





Courses

5 Campuses + distant learning 218 Courses 33 Subjects

Zero fees

Launched in the late 1990s, SITs zero fees proposal was a radical idea to increase population, house prices and provide free education to Southlanders. By 2010, SITs economic impact was estimated at \$210m.

Research


SIT has a strong commitment to supporting and growing research activity. A broad range of research is carried out by staff, reflecting their areas of interests and expertise.

DRIVERS FOR A TRIAL



Key drivers

- SIT Engineering students competed a feasibility study that confirmed it was possible to switch boiler to woodchip
 - Boiler operating at 25% of capacity
 - Conclusion that the fuel feed system should be able to handle the additional requirements of woodchip
- Review of industrial air discharge regulations by Environment Southland
- Environmental leadership
- Funding support from WES





Main objectives

- Prove that the existing boiler is able to operate continuously and autonomously on woodchip while meeting demands for heat output
- Measure the efficiency of the boiler on woodchip and coal
- Record emissions output from the woodchip and coal system
- Provide a potential solution should Environment Southland tighten air discharge requirements in the future for SIT





The process

- Determine which boiler will operate on woodchip and make necessary changes to combustion.
- Arrange for delivery of woodchip into bunker
- Complete air emissions testing for coal and woodchip boiler.
- Return boiler to original coal settings
- Report results to Management





Safety considerations

Several safety issues were identified with the methodology:

- Auger jamming caused by woodchip size
- Burn back of wood fuel into the bunker
 - Mitigation measures
 - Fire hose onsite during trial
 - Small volume of chip in bunker
 - Burn fuel in boiler as a priority to exhaust







Emissions testing

- Carried out by independent auditor (Watercare Ltd)
- Two tests three samples per test
- Conducted under similar flue gas velocity to ensure similar size particles are carried into the flue
- This allowed Watercare to extrapolate data for increased wood volumes

SIT PM10 Emissions		>PM ₁₀	PM ₁₀	Total (TSP)	
		mg/m³, dry, 0 °C, 1 Atm			
Test 1- Coal	1	15.7	43.8	59.5	
	2	18.7	37.0	55.7	
	3	23.5	90.2	113.7	
	Average	19.3	57.0	76.3	
Test 2- Wood	1	3.2	24.0	27.2	
	2	3.3	21.5	24.8	
	3	3.1	15.2	18.4	
	Average	3.2	20.2	23.4	

RESULTS



45-60% REDUCTION

45-60% reduction in PM10 based on 25% and 50% more woodchip being fed into boiler

\$2,240 SAVINGS

There is a small savings as woodchip is slightly cheaper than coal.

425 TCO2-E

Carbon emissions reduction each year

LESSONS LEARNT



- Allocate sufficient time to tune the boiler for woodchip. Should be done prior to the testing and not on the day
- Burn-back is a real issue and occurred during this trial. This needs to be addressed when converting to woodchip
- The design of the auger needs to ensure sufficient fuel is fed to the grate



EMISSIONS FROM OTHER SYSTEMS



Sample		>PM ₁₀	PM ₁₀	Total	>PM ₁₀	PM ₁₀	Total
		mg/m³, dry, 0 °C, 1 Atm			CO ₂ Corrected concentration[1]		
Test 1- Coal	1	280	79	360	530	150	680
	2	270	78	350	510	150	660
	3	320	91	410	670	190	850
	<u>Average</u>	<u>290</u>	<u>83</u>	<u>370</u>	<u>570</u>	<u>160</u>	<u>730</u>
Test 2- Wood	1	3.5	100	105	3.3	96	99
	2	15	78	93	13	71	85
	3	9.9	69	79	9.0	63	72
	<u>Average</u>	9.3	<u>83</u>	<u>92</u>	<u>8.5</u>	<u>77</u>	<u>85</u>

EMISSIONS FROM OTHER SYSTEMS





		>PM ₁₀	PM ₁₀	Condensable	Total	
		(mg/m³, dry , 0°C, 1Atm)				
1 Invercargill	Boiler Un-scrubbed	910	420	540	1870	
Vekos (Coal converted to Wood Chip)	Fresh Water Scrub	50	80	20	150	
2 Vekos (Coal converted to Wood Pellet)	Boiler Un-scrubbed Converted the airflow for wood	11	55	~550	~600	
3 Modern Wood specific Boiler	Boiler Un-scrubbed	54		~200	~250	
4 Modern Vekos boiler	Boiler Un-scrubbed	24		>1000	>1000	
5 Vekos (Coal converted to Wood Pellet)	Boiler Un-scrubbed Converted the airflow for wood Use wet and green wood	56	180	>1000	>1200	
6 Vekos (Coal converted to Wood Pellet)	Boiler Un-scrubbed Use wet and green wood No conversion from coal to wood	1100		>1000	>2000	
7 Vekos (Coal converted to Wood Pellet)	Above but after cyclone	500		>1000	>1500	
8 Vekos (Coal converted to Wood Pellet)	Boiler with Baghouse	20		470	490	
9 Wood Boiler Convertor	Electro Static Precipitator (ESP)	15		tbc	tbc	

